



ENGINEERING EVALUATION REPORT

Issue Date | 2025-01-24
 Expiry Date | 2026-12-31
 Report Number | 0093-26-1-5991
 Client Name | EasyTrim Reveals Inc.
 Address | 101-4441 76th Ave SE, Calgary, AB T2C 2G8

Subject

EasyTrim aluminum trim system ASTM B117 testing. Method of Salt Spray (Fog) Test Results.

Product Description

EasyTrim Reveals aluminum trim is a complete two-piece, exterior aluminum trim system designed for compatibility with various siding products. EasyTrim trims are 15-gauge (1.4mm or 0.055”) thick, available in 10’ long lengths and use 6063-T6 aluminum. Standard finish options include clear anodized (silver matte finish), black anodized, or prime finish.

Evaluation

Testing of the trim has been conducted in accordance with ASTM B117-19, *Method of Salt Spray (Fog) Test* at Intertek – Coquitlam, BC location. Intertek is an independent testing laboratory accredited by the International Accreditation Service (IAS).

Standard	Property	Exposure ¹	Finish Description	Test Results
ASTM B117-19	Corrosion Resistance	1000 hours	Clear Anodized	No corrosion. No signs of any change.
			Black Anodized	No corrosion. Slight discoloured streaking.

1. Test specimens were supported at an angle of 15° from the vertical and were exposed to 35 °C salt fog with 5% sodium chloride solution for 1000 hours.

Source Documents

The published versions of the following sources, current on the date of this evaluation, were used as reference material to support the conclusions made:

- ASTM B117-19 results: Intertek report 105849866COQ-001 R0, dated 2025-01-08.

Signed

This report has been prepared and reviewed on behalf of BOCA by:

2025-01-24

Chris Bowness, P.Eng., P.E.

Date



EVALUATION REPORT TERMS:

- This report is a general evaluation of the building code sections and/or standards requirements as identified and applies only to the samples that were evaluated. It does not imply any endorsement or warranty, nor that the signatory Engineer is the Designer of Record of any construction project for which the information is used.
- This Evaluation Report expires Dec. 31, 2026, open to renewal. Up to the renewal date, the report is valid until such time as the named product(s) changes, the Quality Assurance Agency changes, or provisions of the Code that relate to the product change.

CERTIFICATION OF INDEPENDENCE:

- Boca Engineering Co., its employees and shareholders, do not have, nor do they intend to or will acquire, a financial interest in any company manufacturing or distributing products that they evaluate.
- Boca Engineering Co. is not owned, operated, or controlled by any company manufacturing or distributing products that they evaluate.