



ENGINEERING EVALUATION REPORT

Issue Date	2025-01-24
Expiry Date	2026-12-31
Report Number	0093-27-1-5991
Client Name	EasyTrim Reveals Inc.
Address	101-4441 76th Ave SE, Calgary, AB T2C 2G8

Subject

EasyTrim aluminum trim system. ASTM E136 Fire/Flammability Testing Results.

Product Description

EasyTrim Reveals aluminum trim is a complete two-piece, exterior aluminum trim system designed for compatibility with various siding products. EasyTrim trims are 15-gauge (1.4mm or 0.055") thick, available in 10' long lengths and use 6063-T6 aluminum. Standard finish options include clear anodized (silver matte finish), black anodized, or prime finish.

Evaluation

Testing of the trim has been conducted in accordance with the referenced test standards at Intertek - Coquitlam, BC location. Intertek is an independent testing laboratory accredited by the International Accreditation Service (IAS).

Standard	Property	Sample Description	Test Results
ASTM E136-22	Combustion	EasyTrim Un-Coated Aluminum Trim	Meets requirements of ASTM E136 for non-combustible classification

ASTM E136 is cited in 2024 International Building Code (IBC) section 703.3.1 *Non-combustible materials* and Ch. 35 *Reference standards*.

Source Documents

The published versions of the following sources, current on the date of this evaluation, were used as reference material to support the conclusions made:

1. ASTM E136-22 results: Intertek report 105849866COQ-002 R1, dated 2024-11-22.

Signed

This report has been prepared and reviewed on behalf of BOCA by:

2025-01-24

Chris Bowness, P.Eng., P.E.

Issue Date

EVALUATION REPORT TERMS:

1. This report is a general evaluation of the building code sections and/or standards requirements as identified and applies only to the samples that were evaluated. It does not imply any endorsement or warranty, nor that the signatory Engineer is the Designer of Record of any construction project for which the information is used.
2. This Evaluation Report expires Dec. 31, 2026, open to renewal. Up to the renewal date, the report is valid until such time as the named product(s) changes, the Quality Assurance Agency changes, or provisions of the Code that relate to the product change.

CERTIFICATION OF INDEPENDENCE:

1. Boca Engineering Co., its employees and shareholders, do not have, nor do they intend to or will acquire, a financial interest in any company manufacturing or distributing products that they evaluate.
2. Boca Engineering Co. is not owned, operated or controlled by any company manufacturing or distributing products that they evaluate.

