

Sep 28, 2020

Page 1 of 1

Easy Trim Reveals
4115 72 Ave SE
Calgary, BC T2C 2G5
Canada

Letter Report #: 104352805COQ-006L1
Project #: G104352805

To: Maika Bolia


RE: Test Summary – QuickPanel 4 panel Assembly

Intertek has performed testing on a 4-Panel Assembly of the Easy Trim QuickPanel System with a Fixed Window installed, which was assembled at our lab by Easy Trim Reveals. Testing was performed in accordance with ASTM E331-00. Below is the summary of results for the testing:

Evaluation Property	QuickPanel - 4 Panel Assembly with Fixed Window
Specimen Size	3658 mm x 3048 mm (144.0" x 120.0")
Water Penetration Resistance ASTM E331-00(2009)	Pass @ 720 Pa (15.3 psf)

If you have any questions, please feel free to call us at 604-520-3321.

Best Regards,
INTERTEK TESTING SERVICES NA LTD.


Jason Komorski
Technician – Building Products


David Park
Reviewer – Building Products

